

**From:** Howard, Leslie Ann CIV USN BRAC PMO SAN CA (USA) [leslie.howard@navy.mil]  
**Sent:** Wednesday, March 4, 2020 8:56 AM  
**To:** Stoick, Paul T CIV USN (USA) [paul.stoick@navy.mil]  
**Subject:** FW: D008 CTO-002, Parcel E-2 Landfill Cover - RFI 002  
**Attachments:** RFI 002\_Change in CCs 200228.pdf

Paul

I assume it's ok for me to sign this RFI regarding the RSLs for use at E-2 for Kemron?

Thanks  
Leslie

---

**From:** Lou Ehrhard <lehrhard@kemron.com>  
**Sent:** Tuesday, March 3, 2020 9:44 AM  
**To:** Howard, Leslie Ann CIV USN BRAC PMO SAN CA (USA) <leslie.howard@navy.mil>  
**Cc:** Naimi, Hamidullah CTR NAVFAC SW, ROICC5 <hamidullah.naimi.ctr@navy.mil>; Mark Roberts <mroberts@kemron.com>; Paul Wiseman <paul.wiseman@kemron.com>; HPNS <HPNS@kemron.com>  
**Subject:** [Non-DoD Source] D008 CTO-002, Parcel E-2 Landfill Cover - RFI 002

Leslie -

Please find attached RFI 002 for the subject project. As discussed, the comparison criteria based on the Region 9 RSLs in Table 1 of Specification 31 00 00 are incorrect. We have since corrected these comparison criteria in Data Package #2 that were submitted to you last Friday. This RFI closes the loop on those corrections to the specifications.

Please sign and return for our files. Should you have any questions, please feel free to contact Mark and me. Thanks.

-Lou

---

**Lou Ehrhard** | PG, PMP | Vice President |  
**KEMRON Environmental Services, Inc.**  
*An Employee Owned Company*  
3155 Blackhawk Drive  
Building 599 | Fort Sheridan, IL | 60037 |  
O: 847-266-1350 | Direct: 847-748-7611 |  
(b) (6) | F: 847-266-3584 |  
[KEMRON](#) | [lehrhard@kemron.com](mailto:lehrhard@kemron.com) | [Facebook](#) | [LinkedIn](#)  
**.protecting our environmental future.**

---

**Know Safety, No Accidents**

---

The information contained in this email may be confidential and/or legally privileged. It has been sent for the sole use of the intended recipient(s). If the reader of this message is not an intended recipient, you are hereby notified that any unauthorized review, use, disclosure, dissemination, distribution, or copying of this communication, or any of its contents, is strictly prohibited. If you have received this communication in error, please reply to the sender and destroy all copies of the message. To contact us directly, send to [postmaster@kemron.com](mailto:postmaster@kemron.com). Thank you.

---

REQUEST FOR INFORMATION		ACTIVITY ID	DATE
CONTRACT NO		2.3.4.3	28 Feb 2020
N69450-14-D-0018	CONTRACT TITLE		
RFI SUBJECT	Parcel E2 Landfill Cover Installation	SPEC SECTION	RFI NO
Clean backfill soil comparison criteria		31 00 00	002
RFI PRIORITY?	<input checked="" type="radio"/> HIGH	SPEC PARAGRAPH	DWG NO
POTENTIAL TIME/COST?	<input checked="" type="radio"/> YES	Table 1	DWG DETAIL
SCHEDULE REFERENCED?	<input checked="" type="radio"/> YES	SPEC PAGE NO	NA
CRITICAL PATH?	<input checked="" type="radio"/> YES	6	DWG SHEET NO
Per the Navy RPM, Region 9 RSL values used for comparison criteria in Table 1 of Specification 31 00 00 are incorrect. RSLs with THQ=0.1 were used in the specification instead of RSLs with THQ-1.0. As a result, the comparison criteria based on RSLs identified in Table 1 are one order of magnitude too conservative.			
Incorrect RSLs in the specifications have delayed approval of the backfill soils by the regulatory agencies, thereby impacting the overall implementation and completion of work.			
CONTRACTOR PROPOSED SOLUTION:			
Use THQ=1.0 RSLs as comparison criteria for screening clean backfill soils for those parameters that do not have RGS or HPALs identified in Table 1 of Specification 31 00 00.			
CONTRACTOR/PROJECT MANAGER			
02/28/20		DATE	
RFI ACTION			
COMMENTS FOR DETAILED REVIEWER:			
DETAILED REVIEWER 1 RECOMMENDED RFI SOLUTION:			
DETAILED REVIEWER 1 NAME/SIGNATURE			
TITLE		RESPONSE DATE	
DETAILED REVIEWER 2 RECOMMENDED RFI SOLUTION:			
DETAILED REVIEWER 2 NAME/SIGNATURE			
TITLE		RESPONSE DATE	
RFI RESPONSE:			
GOVERNMENT CONSTRUCTION MANAGER			
DATE			